

**Wireless Multi-Channel Soil
Moisture Sensor**

Model: DP100



Contents

1. Introduction..... 4

| | |
|---|----|
| 2. Get Started | 5 |
| 2.1 Parts List..... | 5 |
| 3. Overview..... | 6 |
| 4. Setup Guide | 8 |
| 4.1 Install batteries | 8 |
| 5. Wi-Fi Configure with gateway..... | 9 |
| 5.1 Pair with Gateway | 10 |
| 5.2 Wi-Fi Connection for the Gateway..... | 11 |
| 6. View Online Data on WS View..... | 12 |

| | |
|-------------------------|-----------------------------|
| 7. Custom mode..... | 15 |
| 8. Specification..... | 29 |
| 9. Warranty Information | Fehler! Textmarke nicht def |

1. Introduction

Thanks for purchasing this Multi-Channel DP100 soil moisture sensor. This device measures soil moisture. The data can be streamed by DP1500 Wi-Fi Gateway(sold

separately) and can be viewed on our WS View mobile application after the Wi-Fi configuration done.

To ensure the best product performance, please read this manual and retain it for future reference.


2. Get Started

2.1 Parts List

One Soil Moisture Sensor

One User Manual


3. Overview



- 1 LED Indicator (RF transmission)
- 2 Battery Cap
- 3 Soil Moisture Sensor

4. Setup Guide

4.1 Install batteries



1. Open the battery cap of the soil moisture sensor

2. Insert one AA battery.

3. After inserting the battery, the remote sensor LED indicator will light for 4 seconds, and then flash once per 70 second thereafter. Each time it flashes, the sensor is transmitting data.

4. Close the battery cap.

5. Insert the sensor totally into the soil of your desired location (after the WIFI configuration done).

5. Wi-Fi Configure with gateway

This soil moisture sensor doesn't has a

display function and you need to use our WS View App to view the data on your mobile application after pairing this device with our DP1500 Wi-Fi Gateway(sold separately).

5.1 Pair with Gateway

If DP1500 has been in operation, and you have never had any DP100 soil moisture sensor setup before, just power up the sensor and DP1500 will pick soil moisture data automatically.

If a DP100 sensor has been hooked on DP1500 before, and you have a new DP100 sensor to replace the old one,

unplug DP1500 from USB socket and power up again, then the new sensor will be learned and old sensor will be erased.

Note: The gateway can support up to 8 soil moisture sensors. The channel is fixed inside the sensor and could not be changed. If you need more than one sensor, please purchase sensor(s) at different channels.

5.2 Wi-Fi Connection for the Gateway

For this part, please refer to the manual of the DP1500 Wi-Fi gateway.

Any question, please contact the customer service.

6. View Online Data on WS View

When the Wi-Fi configuration is done, you can view the live data of your soil moisture sensor on the WS View application.

| Device List Live Data + | |
|---|-------------------|
| GW1000-WIFI885C | |
| Indoor Temperature | Indoor Humidity |
| 28.3 °C | 60 % |
| Outdoor Temperature | Outdoor Humidity |
| 26.0 °C | 65 % |
| Absolute Pressure | Relative Pressure |
| 1012.6 hpa | 1012.6 hpa |
| CH1 Soil | 22 % |
| GW1000_V1.2.7 | |

Note:

The soil moisture data can be only viewed on the Live Data interface since it doesn't support uploads to weather underground.

If you choose to upload the data to our weather server: www.ecowitt.net, you can view the history graph on the website.

7. Custom mode

When in LIVE DATA display mode, you can calibrate the soil moisture sensor by enable the Custom mode.(Click More – Choose Calibration – Choose Soil Calibration – Tick the box on the left side of the Customize).

Live Data

Indoor Temperature: 26.3 °C

Outdoor Temperature: 23.5 °C

Absolute Pressure: 1017.1 hpa

Solar Radiation: 0.0 w/m2

Wind Speed: 0.4 km/h

Wind Gust: 1.8 km/h

RainRate: 0.0 mm

RainDay: 0.3 mm

RainWeek: 0.3 mm

RainMonth: 6.9 mm

RainYear: 6.9 mm

PM2.5: 102.0 ug/m³

CH1 Soil: 11 %

CH2 Temperature: 25.5 °C

Calibration

PM2.5 Gain: 1.00

SolarRad Gain: 1.00

UV Gain: 1.00

Wind Gain: 1.00

Rain Gain: 1.00

InTemp Offset: 0.0 °C

InHumid Offset: 0 %

Abs Offset: 0.0 hpa

Rel Offset: 0.0 hpa

OutTemp Offset: 0.0 °C

OutHumid Offset: 0 %

WindDir Offset: 0 °

Soil Calibration

Reset

Calibration Soil Calibration

CHI Soil Customize

11%

| | |
|--------|-----|
| Now AD | 110 |
| 0%AD | 70 |
| 100%AD | 500 |

Save

Reset

Custom OFF:

Moisture level is calculated based on default dry and wet definition:

Dry (0%AD) AD: 70

Wet (100% AD) AD: 500

$$\text{Soil Moisture} = (\text{moisture AD} - 0\%AD) * 100\% / (100\% AD - 0\%AD)$$

Example: when sensor moisture AD is 310, calculated moisture is:

$$(310 - 70) * 100\% / (500 - 70) = 56\%.$$

This is a fixed slope rate linear system.

Custom ON:

When pot soil at dry or wet condition is not giving the moisture sensor output value that is close to its default assumption, it will give inaccurate moisture level results. It is commonly happening with different soil type that gives very different output value at same moisture level condition. We

introduced this custom mode to make this slope flexible so that it can match your soil type.

This becomes a variable slope rate linear system.

Adjusting principle:

0%AD is used to adjust for dry condition reading inconsistency.

When the displayed moisture readings are too high at dry soil condition, you could lower the slope rate by increasing the 0%AD value.

100%AD is used to adapt for wet condition reading inconsistency.

When the displayed moisture readings are too low at extremely wet soil condition, you could decrease the 100%AD value to fix it.

Please refer to the below example for better understanding.

For example:

When you use this product at the first time, please turn off the custom mode and test

the product at the following two situations:

Situation One:

You watered your potted plant with enough water and the soil should be extremely wet, however the displayed moisture readings is much lower than 95%(e.g.70%).

Solution:

Enable custom mode, and adjust the 100%AD value.

Calculate the 100%AD value with the formula:

$$\text{Soil Moisture} = (\text{moisture AD} - 0\%AD) * 100\% / (100\% AD - 0\%AD)$$

If:

Now AD = 183

0%AD = 70

Target Soil Moisture Reading = 95%

Then:

$$95\% = (183 - 70) * 100\% / (100\%AD - 70)$$

Result: 100%AD= 188(take the Integer part)

Then you can adjust the default 0%AD value to 188 and touch the screen for once to update the data. When you get your expected moisture reading, click Save to save the setting.

Situation Two:

Your potted plant hasn't been watered for very long time and soil is extremely dry. When at this dry condition, displayed moisture readings are much higher than 10%(e.g.40%).

Solution:

Enable the custom mode and adjust the 0%AD value.

Calculate the 0%AD value with the formula:

$$\text{Soil Moisture} = (\text{moisture AD} - 0\%AD) * 100\% / (500 - 0\%AD)$$

If:

Now AD = 183

100%AD = 500

Target Soil Moisture Reading = 10%

Then:

$$10\% = (183 - 0\%AD) * 100\% / (500 - 0\%AD)$$

Result: 0%AD= 147(take the Integer part)

Then you can adjust the default 0%AD value to 147 and touch the screen for once to update the data. When you get your expected moisture reading, click Save to save the setting.

Note: The soil moisture sensor should be inserted totally into the soil for accurate result.

Record the 0%AD and 100%AD value for future use (when WIFI network changed).

8. Specification

Moisture Range:0~100%; Resolution: 1%

0%AD setting range:70~200; Initial value:70

100%AD setting

range:0%AD+10~1000; Initialvalue:500

Frequency: 868 MHz

Sensor reporting interval: 70 seconds

Transmission distance in open field:

100m(300 feet)

Power consumption

- Soil moisture sensor: 1xAA Alkaline batteries (not included)